



Wels, March 09th 2018

DC CURRENT FRONIUS PRIMO 3.0-1 – 8.2-1

Fronius International GmbH

hereby certifies that the inverters

/ Fronius Primo 3.0-1 – 8.2-1

do inject a DC current of $< 0,5 \%$ of the nominal output current into the grid.

Fronius International GmbH

Business Unit Solar Energy

Froniusplatz 1

A-4600 Wels

A handwritten signature in blue ink, appearing to read "Martin Heidl".

DI Dr. Martin Heidl
Head of Systems Technology