



Wels, August 21st 2017

OVERSIZING FRONIUS PRIMO 3.0-1 – 5.0-1

Fronius International GmbH

hereby confirms that the maximum short circuit current (module array) of the inverters

/ Fronius Primo 3.0-1 up to Fronius Primo 5.0-1

which is currently 18A, can be increased to 20amps (MPPT1/MPPT2) without voiding the manufacturer's warranty, provided that

/ string configuration adheres to the voltage and all other current window guidelines published in the operation manual.

Fronius International GmbH

Solar Energy Division
Froniusplatz 1
A-4600 Wels

A handwritten signature in blue ink, appearing to read "Thomas Mühlberger".

DI Thomas Mühlberger
Head of Solution Management